

Building address: Raņķa dambis 3
 Building type: Non-residential
 Year of construction: 1960-1990
 Date: 5-06-2024
 Assessor's name: Edgars Augustiņš



Total SRI Score: 19.7 %
SRI Class: G


IMPACT SCORES

Energy Efficiency:	42.65%
Energy Flexibility and Storage:	9.6%
Comfort:	25.3%
Convenience:	12.5%
Health, well-being and accessibility:	27.78%
Maintenance and fault prediction:	14.98%
Information to occupants:	17.63%



DOMAIN SCORES

Heating:	35.35%
Domestic hot water:	44.58%
Cooling:	0%
Ventilation:	25.76%
Lighting:	0%
Dynamic building envelope:	0%
Electricity:	3.61%
Electric vehicle charging:	0%
Monitoring and control:	9.09%



DETAILED SCORES

Heating:	80 %	0 %	66.7 %	50 %	66.7 %	25 %	33.3 %
Domestic hot water:	66.7 %	33.3 %	0 %	33.3 %	0 %	50 %	33.3 %
Cooling:	0 %	0 %	0 %	0 %	0 %	0 %	0 %
Ventilation:	0 %	0 %	0 %	0 %	42.9 %	50 %	66.7 %
Lighting:	0 %	0 %	0 %	0 %	0 %	0 %	0 %
Dynamic building envelope:	0 %	0 %	0 %	0 %	0 %	0 %	0 %
Electricity:	0 %	0 %	0 %	0 %	0 %	0 %	0 %
Electric vehicle charging:	0 %	0 %	0 %	0 %	0 %	0 %	33.3 %
Monitoring and control:	0 %	0 %	0 %	0 %	0 %	0 %	0 %
Total	12.5 %	11.1 %	33.3 %	5.9 %	0 %	0 %	0 %

Energy Efficiency:	Energy Flexibility and Storage:	Comfort:	Convenience:	Health, well-being and accessibility:	Maintenance and fault prediction:	Information to occupants:
80 %	0 %	66.7 %	50 %	66.7 %	25 %	33.3 %
66.7 %	33.3 %	0 %	33.3 %	0 %	50 %	33.3 %
0 %	0 %	0 %	0 %	0 %	0 %	0 %
0 %	0 %	0 %	0 %	42.9 %	50 %	66.7 %
0 %	0 %	0 %	0 %	0 %	0 %	0 %
0 %	0 %	0 %	0 %	0 %	0 %	0 %
0 %	0 %	0 %	0 %	0 %	0 %	33.3 %
0 %	0 %	0 %	0 %	0 %	0 %	0 %
12.5 %	11.1 %	33.3 %	5.9 %	0 %	0 %	0 %

AGGREGATED SCORES

1:	28.82%
2:	20.8%
3:	9.6%