

Building address: Kojusalas iela 9
 Building type: Non-residential
 Year of construction: < 1960
 Date: 5-06-2024
 Assessor's name: Edgars Augustiņš



Total SRI Score: 12.2 %
SRI Class: G


IMPACT SCORES

Energy Efficiency:	20.56%
Energy Flexibility and Storage:	5.65%
Comfort:	30.84%
Convenience:	13.33%
Health, well-being and accessibility:	20%
Maintenance and fault prediction:	3.1%
Information to occupants:	12.75%



DOMAIN SCORES

Heating:	8.08%
Domestic hot water:	21.69%
Cooling:	0%
Ventilation:	28.79%
Lighting:	0%
Dynamic building envelope:	0%
Electricity:	14.46%
Electric vehicle charging:	0%
Monitoring and control:	9.09%



DETAILED SCORES

Heating:	16.7 %	0 %	12.5 %	12.5 %	33.3 %	0 %	0 %
Domestic hot water:	33.3 %	0 %	0 %	0 %	0 %	50 %	33.3 %
Cooling:	0 %	0 %	0 %	0 %	0 %	0 %	0 %
Ventilation:	36.4 %	0 %	60 %	62.5 %	33.3 %	0 %	0 %
Lighting:	0 %	0 %	0 %	0 %	0 %	0 %	0 %
Dynamic building envelope:	0 %	0 %	0 %	0 %	0 %	0 %	0 %
Electricity:	25 %	0 %	0 %	0 %	0 %	25 %	50 %
Electric vehicle charging:	0 %	0 %	0 %	0 %	0 %	0 %	0 %
Monitoring and control:	12.5 %	11.1 %	33.3 %	5.9 %	0 %	0 %	0 %

	Energy Efficiency:	Energy Flexibility and Storage:	Comfort:	Convenience:	Health, well-being and accessibility:	Maintenance and fault prediction:	Information to occupants:
Heating:	16.7 %	0 %	12.5 %	12.5 %	33.3 %	0 %	0 %
Domestic hot water:	33.3 %	0 %	0 %	0 %	0 %	50 %	33.3 %
Cooling:	0 %	0 %	0 %	0 %	0 %	0 %	0 %
Ventilation:	36.4 %	0 %	60 %	62.5 %	33.3 %	0 %	0 %
Lighting:	0 %	0 %	0 %	0 %	0 %	0 %	0 %
Dynamic building envelope:	0 %	0 %	0 %	0 %	0 %	0 %	0 %
Electricity:	25 %	0 %	0 %	0 %	0 %	25 %	50 %
Electric vehicle charging:	0 %	0 %	0 %	0 %	0 %	0 %	0 %
Monitoring and control:	12.5 %	11.1 %	33.3 %	5.9 %	0 %	0 %	0 %

AGGREGATED SCORES

1:	11.83%
2:	19.23%
3:	5.65%